

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LTD.

(A Government of Chhattisgarh Undertaking)

OFFICE OF THE EXECUTIVE DIRECTOR (S/s O&M)

e-mail : ce_tnc@yahoo.com, Fax : 0771-2574267, CIN-U40108CT2003SGC015820

No.02-07/SE/ 352

Raipur, Dated 23/05/2019

To,
The Executive Director (EITC)
CSPDCL, Raipur.

Sub:- Monthly report of tripping of 33KV Industrial Feeders.
Ref. :- CE (RA&PM) CSPDCL, Raipur letter no. 1195 dtd. 26.07.2018.

---00---

Vide above referred letter, CE (RA&PM) CSPDCL, Raipur has intimated that under Ease of Doing Business, monthly data regarding total duration & frequency of power outage of Industrial feeders is required to be published on public domain. In compliance, tripping details of 33KV Industrial feeders for the month of April-2019 is submitted.

Kindly arrange to upload the data on public domain in the website of CSPTCL/ CSPDCL.

Encl:- Tripping report of 33KV Industrial feeder for the month of April -2019.


Executive Director (S/s-O&M)
CSPTCL, Raipur

Copy to:

The Chief Engineer (RA&PM) CSPDCL, Raipur for information.

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of April -2019.


Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Bhilai	Chhouni Ind.-III	3	0:37
		Simplex	0	0:00
		Industrial	1	0:02
		Chhouni Industrial-II	2	2:01
		Niros Industrial	4	2:40
		Kumhari Ind.	14	5:31
2	132 KV S/S Kurud	33 KV Kurud Ind.	0	0:00
		33 KV Nandani Road Ind.	6	0:44
3	132KV S/S Ruabandha	33KV Baghera feeder	3	0:09
4	132KV S/S Dhamdha	33KV PGCIL	4	0:12

Name of Circle - Bhilai		Name of Division -SS Dn., Rajnandgaon		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Rajnandgaon	33 KV DURG-I	13	0:42
		33 KV SAI CHEMICAL	12	0:39
		33KV INDUSTRIAL	3	0:12
2	132KV S/s Dongargaon	33 KV TUMDIBOD	14	0:42
		33 KV INDUSTRIAL	2	0:06
3	132KV S/S Dallirajhara	33 KV BSP NO-I	3	0:20
		33 KV BSP NO-II	8	0:28
	132KV S/S Rasmada	33 KV RASMADA-I	2	2:43
		33 KV RASMADA-II	1	0:43
		33 KV RASMADA-III	10	2:33
5	132KV S/s Kawardha	33KV Ramhepur	2	0:06
6	132KV S/s Pandariya	33KV SugarFactory	0	0:00

Name of Circle - Raipur		Name of Division -SS Dn.-I		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	220 KV Urla	Shyama	1	0:07
2		C-I	3	0:19
3		URLA-I FEEDER	5	1:32
4		URLA-II FEEDER	6	0:37
5		KABEER NAGAR FEEDER	4	2:11
6		SARORA FEEDER	6	2:27
7		PANKAJ FEEDER	9	6:14
8		HIRA FEEDER	5	2:32
9		INABA FEEDER	5	2:20
10		ALOK FEEDER	4	0:47
11	132 KV Gudhiyari	PIL	6	2:04
12		Biragaon I/C (Out going)	4	0:52
13		Atari (Out going)	2	0:26
14		Shilpi	1	0:03
15		New Kabir Nagar (Out going)	5	2:48

16	132 KV Borjhara	Alankar	2	0:23
17		Balaji	12	7:00
18		Omikiran	1	0:40
19		Alloy	1	0:17
20	132 KV Sector 'C'	BHAVANI FEEDER	1	0:05
21		CHHATTISGARH FEEDER	2	1:20
22		R.NARAYAN FEEDER	2	0:50
23		INDSIL FEEDER	1	0:05
24		RAGHUVIR FEEDER	4	0:35
25		AVINASH FEEDER	0	0:00
26		VANDANA FEEDER	1	0:05
27		RATU SARIYA FEEDER	1	0:05
28		Prakash	2	0:30
29	220/132 KV S/s Siltara	33KV Bhagwati power	0	0:00
30		33 KV Baldev	0	0:00:00
31		33KV Devi Iron	3	10:32
32		33 KV Indian Oil	1	0:51
33		33 KV Jorawar	0	0:00
34		33 KV Aster	1	0:53
35		33 KV C.G. Ispat	5	26:43
36		Bus Coupler Feeder	0	0:00
37		33 KV Hanuman	1	0:10
38		33KV Nandan	0	0:00
39		33KV Mahindra	0	0:00
40		33KV Gagan	8	10:59
41		33 KV New Droliya	Disconnected	
42		33KV Europratik	Disconnected	
43		33KV Cyclepark	3	3:27
44		33KV Rashmi	2	15:49
45		33KV Shyam Iron	3	1:00
46		33 KV API	2	0:00
47		33 KV G.R. Sponge	1	0:20
48		33KV S.K. Sarwangi	0	0:00
49		33KV Gopal	0	0:00
50		33KV Waswani	1	0:35
51		33 KV Sunil spat	2	3:17
52		33KV Droliya cable	2	6:27
53	33 KV Ghankun	1	13:49	
54	132 KV Hira pooling	RR ISPAT FEEDER	1	1:21
55		METAL PARK FEEDER	1	0:30
56		GRAVITY FEEDER	1	0:17
57		VENKATESHWAR FEEDER	2	2:09
58		ROTOCOST FEEDER	0	0:00
59		SAURABH FEEDER	1	0:12
60		SIMGA FEEDER	21	3:10
61		SILTARA FEEDER	17	15:29
62		Mahesh	6	4:30
63		AIR FEEDER	10	1:18
64		RAIPUR INTER CONN.	5	2:54

65	132 KV Birgaon	URLA -I FEEDER	3	2:08
66		HTC-III FEEDER	1	0:20
67		SIMPLEX FEEDER	0	0:00
68		HTC-II FEEDER	5	2:49
69		URLA-II FEEDER	6	3:07
70		HTC-I FEEDER	4	1:55
71		Biragaon-Mandir hausad	2	0:13
72	132 KV Tulsi	HT Feeder (Tulsi)	2	0:08


Executive Engineer
O/o Executive Director (S/s-O&M)
CSPTCL, Raipur